

Analysis of Harmonics Generated by Different Structures of a DC EAF

DJEGHADER.Y, LABAR.H, BOUNAYA.K

Abstract DC electric arc furnace is an important nonlinear time-varying load in power system. Due to the adverse effects produced by the operation of arc furnace, it is important to build a practical model to describe the behaviour of electric arc furnace. This paper presents a DC Electric Arc Furnace the model is based on the stochastic nature of the electric arc current-voltage characteristic. Our model is consisting of four different structures basing on utilization of twelve power rectifiers for the study of harmonics in electrical networks. The model has been implemented using a numerical simulation environment to facilitate later analysis. Finally, the simulation results are compared with different structures of a DC EAF, when the Total Harmonic Distortion (THD) is determined and spectral representation to compares each structure is better in order.

Keywords: DC EAF, Electrical arc, Harmonics, Power Quality, Simulation

I. Introduction

The quality of power supply is very important nowadays. The dc arc furnaces, among others, generate a wide spectrum of harmonics, which deteriorate the quality of the delivered energy, increases the energy losses and decreases the reliability of a power system [1, 10].

The precise control of chemistry and temperature encouraged use of electric arc furnaces during World War II for production of steel for shell casings [2]. Today steelmaking arc furnaces produce many grades of steel, from concrete reinforcing bars and common merchant-quality standard channels, bars, and flats to special bar quality grades used for the automotive and oil industry [11].

DC Arc furnace is the most versatile means for melting ferrous metals. Until recently, AC Arc Furnaces were used for melting as generation & distribution of AC power was convenient

But with the progress in thyristor Technology, DC Supply has become a genuine alternative to AC Supply [5, 6].

II. Furnace operations

The electric arc furnace operates as a batch melting process producing batches of molten: steel known "heats". The electric arc furnace operating cycle is called the tap-to-tap cycle and is made up of the following operations [4]

- Furnace charging
- Melting
- Refining
- De- slagging
- Tapping
- Furnace turn-around

Modern operations aim for a tap-to-tap time of less than 60 minutes. Some twin shell furnace operations are achieving tap-to-tap times of 35 to 40 minutes [7, 8]

III. Advantage of D.C. Arc Furnace

DC mode of operation ensures high arc stability, eliminates inrush currents and disturbances in Power System [3].

- Reduce metal loss by 2 - 4 -5 %.
- Reduces electrode consumption by 60%.
- Lower energy consumption by 5 - 7%.
- Absence of Hot Spots and Lower refractory consumption by 20%.
- DC flicker is 20% of AC flickers as current control reduces fluctuation of reactive power, Can also work on weak lines.
- Homogeneous temperature & composition due to intense stirring in molten metal.
- Ability to melt high percentage of DRI in the charge.
- Fewer mechanical components with less wear & tear reduce maintenance costs to only 40%.
- Environment friendly system with lower dust load by 80% & hence lower cost of pollution control equipment by 50%.
- UNIARC does not require Static VA Compensators for operation

IV. Model description

Our EAF melt steel, is applying by a DC current to load steel scrap by means of graphite electrodes. Compose essentially a 225/63 kV step-down transformer, and a second three wind transformer, one is coupled star and the other in a triangle, feeds a twelve pulse rectifier as shown in the following figure.




Fig. 1 Modelled dc arc furnace plant

The opportunities of the DC EAF simulator is mainly based on the release of twelve pulse rectifier (i.e. the number of electrodes used 1, 2, 3), as well as the use of neutral connection. A typical DC arc furnace plant, is modelled as it is shown in Fig. 1,

V. Twelve pulse rectifier

The principle consists in using a transformer with two secondary delivering voltage delayed of 30° between them, each of these secondary supply a rectifier in bridge of Graëtz that achieves a 12 pulses DC current [5].

So this structure regroups two converters. A bridge, with a $\lambda\lambda$ connection (PD3) and another bridge $\lambda\Delta$ connection (S3).

The rectifiers must provide identical continuous currents so that the alternating currents in the secondary of the transformers take the same values.

In these conditions, there is a recombination of the harmonic currents, generated by each of the rectifiers to the primary of the transformer and the calculation shows that the harmonic of rang $6k \pm 1$ are eliminated.




Fig. 2 Twelve pulse rectifier

The first is three phase to a connection star / star, therefore its current profile is represented as follows.




Fig. 3 Current at the star of transformer rectifier

The second is three phase set to a connection star / triangle, therefore its current profile is represented as follows




Fig. 4 Current at the triangle of transformer rectifier

The recombination of the two rectifiers' gives a bigger current with fewer harmonic (harmonic 5 and 7 are nil) and its current shape is as follows




Fig. 5 Current of twelve pulse rectifier

Structure N°01: we use three electrodes is a DC EAF phase as shown in figure .6




Fig. 6 Structure 01 of a DC EAF

Structure N°02: we use two electrodes therefore a DC two-phase EAF as shown in figure .7




Fig. 7 Structure 02 of a DC EAF

Structure N°03: we use two electrodes therefore a DC two-phase EAF with neutral loop as shown on the figure.8




Fig. 8 Structure 03 of a DC EAF

Structure N°04: we use only one electrode therefore a DC EAF single phase with neutral loop as shown on the figure.9




Fig. 9 Structure 04 of a DC EAF

VI. Model of arc furnace

According to the results of convenient measure we can draw the variation of the resistance and the reactance of the bow according to the distance between the electrodes and scrap as shown on the following figures:




Fig. 10 Variation of Xarc




Fig. 11 Variation of Rarc

Following to the treatment an empirical model is proposed:

$$R_{arc} = A_R(u)e^{\alpha(u)d}$$

Where

$$A_R = \frac{[0,7.(U - 210)^2 + 1,7]}{50^2} \cdot 10^{-3} ;$$

$$\alpha = 0,097e^{0,011(90-U)} - \frac{1,7}{(U - 112)^2 + 80} + \frac{100}{(U - 360)^2 + 50}$$

$$X_{arc} = A_X(u)d^2 + B_X(u) ; \text{ Where}$$

$$A_X = 1,05 \cdot 10^{-3} e^{0,075(90-U)} ;$$

$$B_X = \frac{3,14}{153} - 3 \cdot 10^{-3} e^{0,075(90-U)}$$

d - Is the distance between electrode and scrap



VII. Harmonic analysis

We know that with the use of twelve pulse rectifiers the existing harmonics are characterised by following relationship: $12k \pm 1$, [9]. But experience and analysis of the results also highlight a number of non-harmonic characteristics, amplitude non-negligible, especially in the area of low frequencies (harmonics ranges from 2 to 10) [12]. Our analysis based on the speed of the current spread in the electric network and determine their total harmonic distortion, and their harmonic spectrum which shows the dominant harmonics that are in this flow, and according to these criteria we make a comparison between proposed structures and draws the best that provides a good quality of energy characterized by a low THD



VIII. Different proposed structures

In these tables we represent the shapes of the current and the spectres of harmonic correspond to the different structures with the values of the THD.



Structure N°01 : THD=12,05%





Structure N°03 : THD=12,07%



Structure N°02 : THD=12,03%



Structure N°04 : THD=13,48%



IX. Comments & discussion

According to the results of the simulation we pull the following findings

- We note that the four structures offer a THD between 12 and 14 % it is acceptable and under the norms.
- The harmonic 11 and 13 always exist and in the different structures with important magnitudes
- The proposition N°02 is the best between the proposed structures, since its minimum THD
- The structure with only one electrode is the worst case
- The three phase structure generate important low-frequency harmonics

X. Conclusion

This paper presents a new DC Electric Arc Furnace model which implanted under numerical environment.

- We have describe four proposed structures based in utilization of number of motoring electrodes and fixed one , So the simulation results according to this new models are shown, and compared.
- The chose of each structure is based on the harmonics values under the achieved power quality.
- To optimize the working of the DC EAF and to eliminate the harmonic it is sufficient to install two filters tuned to the rang 11 and 13.

References

- [1] G. Carpinelli, F. Iacovone, A. Russo and P.Varilone, "Chaos-based modeling of DC arc furnaces for power quality issues," in *IEEE Transactions on Power Delivery*, Vol. 19, No. 4, October 2004, pp. 1869-1876.
- [2] Omer Ozgun and Ali Bur, "Development of an Arc Furnace Model for Power Quality Studies," Power Engineering Society Summer Meeting, 1999 IEEE, pp.507-511, July 1999.
- [3]G. Carpinelli, F. Iacovone, A. Russo, P. Verde and D. Zaninelli, "DC Arc Furnaces: Comparison of Arc Models to Evaluate Waveform Distortions and Volt-age Fluctuations", Proc. 2001 IEEE PES 33th Annual North American Power Symposium (NAPS), College Station (Texas), 2001, pp. 574-580.
- [4] Sarshar A., Sharp M., "Analysis of harmonic and transient phenomena due to operation of an arc furnace", *Iron & steel engineer*, vol. 73, no. 4, pp 78-82, Assoc. iron & steel Eng. USA, April, 1996.
- [5] K. Timm, "Electric principles of DC-furnaces," *Electrical Engineering of Arc Furnaces Symposium*, Kehl, Germany, 18-21 April 2005.
- [6]A. Bracale, G. Carpinelli, Z. Leonowicz, T. Lobos, J. Rezmer. "Waveform Distortions due to AC/DC Converters Feeding Dc Arc Furnaces", *Trans. of EPQU 05 Conference*, Cracow, Poland, 2005, sub-mitted
- [7] M. Wursteisen, J. Du Parc and C. Glinski, "Converters with low disturbances for the electric

power supply of DC furnaces," 5th European Electric Steel Congress, Paris, 1995.

[8] E.A. Cano Plata, H.E. Tacca, "Arc furnace modelling in ATP-EMTP," *International Conference on Power Systems Transients IPST'05*, Montréal, Canada, 2005.

[9] Omer Ozgun and Ali Bur, "Development of an Arc Furnace Model for Power Quality Studies," *Power Engineering Society Summer Meeting*, 1999 IEEE, pp.507-511, July 1999.

[10] H. Schau, D. Stade, "Mathematical modeling of three-phase arc furnaces". In *Proceedings of the IEEE-ICHPS II*, Bologna, September 1994, pp 422-428..

[11] Tongxin Zhang, Elham B. Makram, "An Adaptive Arc Furnace Model," *IEEE Trans. Power Delivery*, Vol. 15, pp. 931-939, July 2000.

[12] D. Stade, H. Schan and S. Kramer, "Modelling of the electrical behaviour of arc furnace," in *Proc. 29th Universities Power Engineering Conference*, Vol.1, 1994, pp. 125-128.